

REROOFING AND RELATED WORK

**BADALATO AND SZCZESNY
PARKING GARAGES**

NEW BRITAIN, CONNECTICUT

CHANGES TO SPECIFICATIONS:

SECTION 07550 - MEMBRANE ROOFING, SHEET METAL, AND RELATED WORK

1.04 MEMBRANE ROOFING AND RELATED WORK

A. MATERIALS

5. TOP LAYER INSULATION

Change: 3/8" Dens-Deck (Primed) to 1/2" Dens-Deck (Primed)

CHANGES TO DRAWINGS:

DRAWING R-2

Clarification: Insulation to be tapered at 1/8" per linear foot with a minimum thickness of 1/2" at low point. Tapered insulation crickets to be tapered at 1/4" per linear foot.

END OF ADDENDUM NO. 2